



OFFICE OF THE DEPUTY FIRE OFFICER
BALASORE CIRCLE BALASORE

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

Certificate No-11/BLS CLE

Dt-11.04.2019

This certificate is valid up to **10.04.2021**

(Apply for renewal at least three months before expiry)

Certified that G+3 floors St. Thomas Convent School, over plot No-359/913, Khata No-158/624, Kalidaspur, Dist-Balasore consisting of total 01 (one) block was inspected by officers of Odisha Fire Service on 18.11.2018 in presence of the Principal St. Thomas Convent School, Kalidaspur, Dist-Balasore and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules, 2017. Further, in pursuance of Govt. of Odisha Home department resolution No-19875 dated.03.05.2018, "consent of satisfaction" has been issued by BRIT, Balasore Regional Improvement Trust, Balasore vide Letter No-469, dated 28.01.2019 in respect of items vide Sl. No-1 to 17 of FORM-IV of Odisha Fire Prevention and Fire safety Rules, 2017. Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:

Ground + 3rd floor----- usage----- Educational

CONDITIONS:-

1. Fire Prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier (S) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (S) shall train all staff and occupants periodically to make them well conversant in use and operation of fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all tower/blocks of building/premises.


Ramesh Chandra Sethy
11.4.19

(Ramesh Chandra Sethy)
Deputy Fire Officer
Balasore Circle, Balasore

Memo No.882/BLS CLE

date.11.04.2019

Copy to Principal, St. Thomas Convent School, Kalidaspur, Dist-Balasore for information and necessary action.



(Ramesh Chandra Sethy)

Deputy Fire Officer

Balasore Circle, Balasore

Deputy Fire Officer**Balasore Circle, Balasore**

Memo No- (2)/BLS CLE

date. .04.2019

Copy submitted to the Chief Fire Officer, Fire Prevention Wing, Directorate, Cuttack / Fire Officer, Central Range, Cuttack for information please.

Sd/-

(Ramesh Chandra Sethy)

Deputy Fire Officer

Balasore Circle, Balasore

Memo No. /BLS CLE

date. .04.2019

Copy to Chairman, BRIT, Balasore Regional Improvement Trust, Balasore for information with his reference to Letter No-469, dated 28.01.2019.

Sd/-

(Ramesh Chandra Sethy)

• Deputy Fire Officer

Balasore Circle, Balasore